



Alarm Monitoring and Management

This chapter describes Cisco Transport Controller (CTC) alarm management. To troubleshoot specific alarms, refer to the *Cisco ONS 15310-CL and ONS 15310-MA Troubleshooting Guide*. Chapter topics include:

- [11.1 Overview, page 11-1](#)
- [11.2 Viewing Alarms, page 11-1](#)
- [11.3 Alarm Severities, page 11-9](#)
- [11.4 Alarm Profiles, page 11-10](#)
- [11.5 Alarm Suppression, page 11-13](#)
- [11.6 External Alarms and Controls, page 11-13](#)

11.1 Overview

Cisco Transport Controller (CTC) detects and reports SONET alarms generated by the Cisco ONS 15310-CL or ONS 15310-MA and the larger SONET network. You can use CTC to monitor and manage alarms at the card, node, or network level. Default alarm severities conform to the Telcordia GR-474-CORE standard, but you can set alarm severities in customized alarm profiles or suppress CTC alarm reporting. For a detailed description of the standard Telcordia categories employed by Optical Networking System (ONS) nodes, refer the *Cisco ONS 15310-CL and Cisco ONS 15310-MA Procedure Guide*.



Note

ONS 15310-CL and ONS 15310-MA alarms can also be monitored and managed through Transaction Language One (TL1) or a network management system (NMS).

11.2 Viewing Alarms

You can use the Alarms tab to view card, node, or network-level alarms. The Alarms window shows alarms in conformance with Telcordia GR-474-CORE. This means that if a network problem causes two alarms, such as loss of frame (LOF) and loss of signal (LOS), CTC only shows the LOS alarm in this window because it supersedes LOF. (The LOF alarm can still be retrieved in the Conditions window.)

The Path Width column in the Alarms and Conditions tabs expands upon alarmed object information contained in the access identifier (AID) string (such as “STS-4-1-3”) by giving the number of synchronous transport signals (STSS) contained in the alarmed path. For example, the Path Width will tell you whether a Critical alarm applies to an STS1 or an STS48c. The column reports the width as a 1, 3, 6, 12, 48, etc. as appropriate, understood to be “STS-N.”

Table 11-1 lists the Alarms tab column headings and the information recorded in each column.

Table 11-1 Alarms Column Descriptions

Column	Information Recorded
New	Indicates a new alarm. To change this status, click either the Synchronize button or the Delete Cleared Alarms button.
Date	Date and time of the alarm.
Node	Shows the name of the node where the condition or alarm occurred. (Visible in network view.)
Object	TL1 AID for the alarmed object. For an STSmon or VTmon, this is the monitored STS or VT object, which is explained in Table 11-3 on page 11-3 .
Eqpt Type	Card type in this slot (appears only in network and node view).
Shelf	For DWDM configurations, the shelf where the alarmed object is located. Visible in network view.
Slot	Slot where the alarm occurred (appears only in network and node view).
Port	Port where the alarm is raised. For STSTerm and VTTerm, the port refers to the upstream card it is partnered with.
Path Width	Indicates how many STSS are contained in the alarmed path. This information compliments the alarm object notation, which is explained in Table 11-3 on page 11-3 .
Sev	Severity level: CR (Critical), MJ (Major), MN (Minor), NA (Not-Alarmed), NR (Not-Reported).
ST	Status: R (raised), C (clear).
SA	When checked, indicates a service-affecting alarm.
Cond	The error message/alarm name. These names are alphabetically defined in the “Alarm Troubleshooting” chapter of the <i>Cisco ONS 15310-CL and ONS 15310-MA Troubleshooting Guide</i> .
Description	Description of the alarm.
Num	Num (number) is the quantity of alarm messages received and is increments automatically as alarms occur to display the current total of received error messages. (The column is hidden by default; to view it, right-click a column and choose Show Column > Num .)
Ref	Ref (reference) is a unique identification number assigned to each alarm to reference a specific alarm message that is displayed. (The column is hidden by default; to view it, right-click a column and choose Show Column > Ref .)

Table 11-2 lists the color codes for alarm and condition severities. In addition to the severities listed in the table, CTC alarm profiles list inherited (I) and unset (U) severities.

Table 11-2 Color Codes for Alarm and Condition Severities

Color	Description
Red	Raised Critical (CR) alarm
Orange	Raised Major (MJ) alarm
Yellow	Raised Minor (MN) alarm
Magenta	Raised Not-Alarmed (NA) condition
Blue	Raised Not-Reported (NR) condition
White	Cleared (C) alarm or condition

In network view, CTC identifies STS and VT alarm objects using a TL1-type AID, as shown in [Table 11-3](#).

Table 11-3 STS and Alarm Object Identification

STS and VT Alarm Numbering (ONS 15310-CL and ONS 15310-MA)	
MON Object (Optical)	Syntax and Examples
OC3/OC12 STS	Syntax: STS-<Slot>-<Ppm>-<Port>-<STS> Ranges: STS- $\{2\}$ - $\{1-2\}$ - $\{1\}$ - $\{1-n\}$ ¹ Example: STS-2-1-1-6
OC3/OC12 VT	Syntax: VT1-<Slot>-<Ppm>-<Port>-<STS>-<VT Group>-<VT> Ranges: VT1- $\{2\}$ - $\{1-2\}$ - $\{1\}$ - $\{1-n\}$ - $\{1-7\}$ - $\{1-4\}$ Example: VT1-2-1-1-6-1-1
EC1 STS	Syntax: STS-<Slot>-<Port>-<STS> Ranges: STS- $\{2\}$ - $\{1-3\}$ - $\{1-n\}$ ¹ Example: STS-2-1-6
EC1 VT	Syntax: VT1-<Slot>-<Port>-<STS>-<VT Group>-<VT> Ranges: VT1- $\{2\}$ - $\{1-3\}$ - $\{1-n\}$ ¹ - $\{1-7\}$ - $\{1-4\}$ Example: VT1-2-1-6-1-1
TERM Object (Electrical)	Syntax and Examples
T1 STS	Syntax: STS-<Slot>-<STS> Ranges: STS- $\{2\}$ - $\{1-n\}$ ¹ Example: STS-2-6
T1 VT	Syntax: VT1-<Slot>-<STS>-VT Group-<VT> Ranges: VT1- $\{2\}$ - $\{1-n\}$ ¹ - $\{1-7\}$ - $\{1-3\}$ Example: VT1-2-6-1-1
T3 STS	Syntax: STS-<Slot>-<Port>-<STS> Ranges: STS- $\{2\}$ - $\{1-3\}$ - $\{1-n\}$ ¹ Example: STS-2-1-6
T3 VT	VT not supported

1. The maximum number of STSs depends on the rate and size of the STS.

11.2.1 Viewing Alarms With Each Node's Time Zone

By default, alarms and conditions are displayed with the time stamp of the CTC workstation where you are viewing them. But you can set the node to report alarms (and conditions) using the time zone where the node is located by clicking Edit > Preferences, and clicking the Display Events Using Each Node's Timezone check box.

11.2.2 Controlling Alarm Display

You can control the display of the alarms shown in the Alarms window. [Table 11-4](#) shows the actions you can perform in the Alarms window.

Table 11-4 Alarm Display

Button/Check box/Tool	Action
Filter button	Allows you to change the display in the Alarms window to show only alarms that meet a certain severity level, occur in a specified time frame, and/or reflect specific conditions. For example, you can set the filter so that only Critical alarms are displayed in the window. If you enable the Filter feature by clicking the Filter tool in one CTC view, such as node view, it is enabled in the others as well (card view and network view).
Synchronize button	Updates the alarm display. Although CTC displays alarms in real time, the Synchronize button allows you to verify the alarm display. This is particularly useful during provisioning or troubleshooting.
Delete Cleared Alarms button	Deletes, from the view, alarms that have been cleared.
AutoDelete Cleared Alarms check box	If checked, CTC automatically deletes cleared alarms.
Filter tool	Enables or disables alarm filtering in the card, node, or network view. When enabled or disabled, this state applies to other views for that node and for all other nodes in the network. For example, if the Filter tool is enabled in the node (default login) view Alarms window, the network view Alarms window and card view Alarms window also show the tool enabled. All other nodes in the network also show the tool enabled.


11.2.3 Filtering Alarms

The alarm display can be filtered to prevent display of alarms with certain severities or alarms that occurred between certain dates and times. You can set the filtering parameters by clicking the Filter button at the bottom-left of the Alarms window. You can turn the filter on or off by clicking the Filter tool at the bottom-right of the window. CTC retains your filter activation setting. For example, if you turn the filter on and then log out, CTC keeps the filter active the next time you log in.

11.2.4 Viewing Alarm-Affected Circuits

To view which ONS 15310-CL or ONS 15310-MA circuits are affected by a specific alarm, right-click an alarm in the Alarm window. A shortcut menu appears, as shown in Figure 11-1. (This figure illustrates the ONS 15310-MA Select Affected Circuits shortcut menu, but the ONS 15310-CL menu is identical.) When you select the Select Affected Circuits option, the Circuits window opens to show the circuits that are affected by the alarm.

Figure 11-1 ONS 15310-MA Select Affected Circuits Option



11.2.5 Conditions Tab

The Conditions window displays retrieved fault conditions. A condition is a fault or status detected by ONS 15310-CL and ONS 15310-MA hardware or software. When a condition occurs and continues for a minimum period, CTC raises a standing condition, which is a flag showing that this particular condition currently exists on the ONS 15310-CL or ONS 15310-MA.

The Conditions window, in contrast with the Alarms window, shows all conditions that occur, including those that are superseded. For instance, if a network problem causes two alarms, such as LOF and LOS, CTC shows both the LOF and LOS conditions in this window (even though LOS supersedes LOF). Having all conditions visible can be helpful when troubleshooting the ONS 15310-CL or ONS 15310-MA. If you want to retrieve conditions that obey a root-cause hierarchy (that is, LOS supersedes and replaces LOF), you can exclude the same root causes by checking “Exclude Same Root Cause” check box in the window.

Fault conditions include reported alarms and Not-Reported or Not-Alarmed conditions. Refer to the trouble notifications information in the *Cisco ONS 15310-CL and ONS 15310-MA Troubleshooting Guide* for more information about alarm and condition classifications.

11.2.6 Controlling the Conditions Display

You can control the display of the conditions on the Conditions window. [Table 11-5](#) shows the actions you can perform in the window.

Table 11-5 *Conditions Display*

Button	Action
Retrieve	Retrieves the current set of all existing fault conditions (maintained by the alarm manager) from the ONS 15310-CL and ONS 15310-MA.
Filter	Allows you to change the Conditions window display to only show the conditions that meet a certain severity level or occur in a specified time. For example, you can set the filter so that only Critical conditions display on the window. There is a Filter tool on the lower-right of the window that allows you to enable or disable the filter feature.

11.2.6.1 Retrieving and Displaying Conditions

The current set of all existing conditions maintained by the alarm manager can be seen when you click the Retrieve button. The set of conditions retrieved is relative to the view. For example, if you click the button while displaying the node view, node-specific conditions appear. If you click the button while displaying the network view, all conditions for the network (including ONS 15310-CL and ONS 15310-MA nodes and other connected nodes) appear, and the card view shows only card-specific conditions.

You can also set a node to display conditions using the time zone where the node is located, rather than the time zone of the PC where they are being viewed. Refer to the *Cisco ONS 15310-CL and ONS 15310-MA Procedure Guide* for instructions.

11.2.6.2 Conditions Column Descriptions

[Table 11-6](#) lists the Conditions window column headings and the information recorded in each column.

Table 11-6 *Conditions Column Description*

Column	Information Recorded
Date	Date and time of the condition.
Node	Shows the name of the node where the condition or alarm occurred. (Visible in network view.)
Object	TL1 AID for the condition object. For an STSmon or VTmon, this is the monitored STS or VT object, which is explained in Table 11-3 on page 11-3 .
Eqpt Type	Card type in this slot (appears only in network and node view).
Shelf	For DWDM configurations, the shelf where the alarmed object is located. Visible in network view.

Table 11-6 Conditions Column Description (continued)

Column	Information Recorded
Slot	Slot where the condition occurred (appears only in network and node view).
Port	Port where the condition occurred. For STSTerm and VTSTerm, the port refers to the upstream card it is partnered with.
Path Width	Width of the signal path
Sev ¹	Severity level: CR (Critical), MJ (Major), MN (Minor), NA (Not-Alarmed), NR (Not-Reported).
SA ¹	Indicates a service-affecting alarm (when checked).
Cond	The error message/alarm name; these names are alphabetically defined in the <i>Cisco ONS 15310-CL and ONS 15310-MA Troubleshooting Guide</i> .
Description	Description of the condition.

1. All alarms, their severities, and service-affecting statuses are also displayed in the Condition tab unless you choose to filter the alarm from the display using the Filter button.

11.2.6.3 Filtering Conditions

The condition display can be filtered to prevent the appearance of conditions (including alarms) with certain severities or that occurred between certain dates. You can set the filtering parameters by clicking the Filter button at the bottom-left of the Conditions window. You can turn the filter on or off by clicking the Filter tool at the bottom-right of the window. CTC retains your filter activation setting. For example, if you turn the filter on and then log out, CTC keeps the filter active the next time you log in.

11.2.7 Viewing History

The History window displays historic alarm or condition data for the node or for your login session. You can choose to display only alarm history, only events, or both by checking check boxes in the History > Shelf window. You can view network-level alarm and condition history, such as for circuits, for all the nodes visible in network view. At the node level, you can see all port (facility), card, STS, and system-level history entries for that node. For example, protection-switching events or performance-monitoring threshold crossings appear here. If you double-click a card, you can view all port, card, and STS alarm or condition history that directly affects the port.



Note

In the Preference dialog General tab, the Maximum History Entries value only applies to the Session window.

Different views of CTC display different kinds of history:

- The History > Session window is shown in network view, node view, and card view. It shows alarms and conditions that occurred during the current user CTC session.
- The History > Shelf window is only shown in node view. It shows the alarms and conditions that occurred on the node since CTC software was operated on the node.
- The History > Card window is only shown in card view. It shows the alarms and conditions that occurred on the card since CTC software was installed on the node.

**Tip**

Double-click an alarm in the History window to display the corresponding view. For example, double-clicking a card alarm takes you to card view. In network view, double-clicking a node alarm takes you to node view.

If you check the History window Alarms check box, you display the node history of alarms. If you check the Events check box, you display the node history of Not Alarmed and transient events (conditions). If you check both check boxes, you retrieve node history for both.

11.2.7.1 History Column Descriptions

Table 11-7 lists the History window column headings and the information recorded in each column.

Table 11-7 History Column Description

Column	Information Recorded
Num	An incrementing count of alarm or condition messages. (The column is hidden by default; to view it, right-click a column and choose Show Column > Num.)
Ref	The reference number assigned to the alarm or condition. (The column is hidden by default; to view it, right-click a column and choose Show Column > Ref.)
Date	Date and time of the condition.
Node	Shows the name of the node where the condition or alarm occurred. (Visible in network view.)
Object	TL1 AID for the condition object. For an STSmon or VTmon, this is the monitored STS or VT object, which is explained in Table 11-3 on page 11-3 .
Eqpt Type	Card type in this slot (only displays in network view and node view).
Shelf	For DWDM configurations, the shelf where the alarmed object is located. Visible in network view.
Slot	Slot where the condition occurred (only displays in network view and node view).
Port	Port where the condition occurred. For STSTerm and VTTerm, the port refers to the upstream card it is partnered with.
Path Width	Width of the signal path.
Sev	Severity level: Critical (CR), Major (MJ), Minor (MN), Not-Alerted (NA), Not-Reported (NR).
ST	Status: raised (R), cleared (C), or transient (T).
SA	A service-affecting alarm (when checked).
Description	Description of the condition.
Cond	Condition name.

11.2.7.2 Retrieving and Displaying Alarm and Condition History

You can retrieve and view the history of alarms and conditions, as well as transients (passing notifications of processes as they occur) in the CTC history window. The information in this window is specific to the view where it is shown (that is, network history in the network view, node history in the node view, and card history in the card view).

The node and card history views are each divided into two tabs. In node view, when you click the Retrieve button, you can see the history of alarms, conditions, and transients that have occurred on the node in the History > Shelf window, and the history of alarms, conditions, and transients that have occurred on the node during your login session in the History > Session window. In the card-view history window, after you retrieve the card history, you can see the history of alarms, conditions, and transients on the card in the History > Card window, or a history of alarms, conditions, and transients that have occurred during your login session in the History > Session window. You can also filter the severities and occurrence period in these history windows.

11.2.8 Alarm History and Log Buffer Capacities

The ONS 15310-CL or ONS 15310-MA alarm history log, stored in the 15310-CL-CTX and CTX2500 RSA memory, contains four categories of alarms. These include:

- CR severity alarms
- MJ severity alarms
- MN severity alarms
- the combined group of cleared, Not Alarmed severity, and Not Reported severity alarms

Each category can store between 4 and 640 alarm chunks, or entries. In each category, when the upper limit is reached, the oldest entry in the category is deleted. The capacity is not user-provisionable.

CTC also has a log buffer, separate from the alarm history log, that pertains to the total number of entries displayed in the Alarms, Conditions, and History windows. The total capacity is provisionable up to 5,000 entries. When the upper limit is reached, the oldest entries are deleted.

11.3 Alarm Severities

The ONS 15310-CL and ONS 15310-MA alarm severities follow the Telcordia GR-474-CORE standard, so a condition may be Alarmed at a severity of Critical (CR), Major (MJ), or Minor (MN) with a severity of Not Alarmed (NA) or Not Reported (NR). These severities are reported in the CTC software Alarms, Conditions, and History windows at all levels: network, node, and card.

ONS equipment provides a standard profile named “Default” that lists all alarms and conditions with severity settings based on Telcordia GR-253-CORE and other standards, but users can create their own profiles with different settings for some or all conditions and apply these wherever needed. (See the [“11.4 Alarm Profiles” section on page 11-10](#) for more information.) For example, in a custom alarm profile, the default severity of a carrier loss (CARLOSS) alarm on an Ethernet port can be changed from Major to Critical.

Critical and Major severities are only used for service-affecting alarms. If a condition is set as Critical or Major by profile, it will raise as a Minor alarm in the following situations:

- In a protection group, if the alarm is on a standby entity (side not carrying traffic)
- If the alarmed entity has no traffic provisioned on it, so no service is lost

Because the alarm might be raised at two different levels, the alarm profile pane shows Critical as “CR / MN” and Major as “MJ / MN.”

11.4 Alarm Profiles

The alarm profiles feature allows you to change default alarm severities by creating unique alarm profiles for individual ONS 15310-CL or ONS 15310-MA ports, cards, or nodes. A created alarm profile can be applied to any node on the network. Alarm profiles can be saved to a file and imported elsewhere in the network, but the profile must be stored locally on a node before it can be applied to the node, cards, or ports.

CTC can store up to ten active alarm profiles at any time to apply to the node. Custom profiles can take eight of these active profile positions. Two other profiles, Default profile and Inherited profile, are reserved by the NE, and cannot be edited. The reserved Default profile contains Telcordia GR-474-CORE severities. The reserved Inherited profile allows port alarm severities to be governed by the card-level severities, or card alarm severities to be determined by the node-level severities.

If one or more alarm profiles is stored as files from elsewhere in the network onto the local PC or server hard drive where CTC resides, you can use as many profiles as you can physically store by deleting and replacing them locally in CTC so that only eight are active at any given time.

11.4.1 Creating and Modifying Alarm Profiles

Alarm profiles are created in the network view using the Provisioning > Alarm Profiles tabs. A default alarm severity following Telcordia GR-474-CORE standards is preprovisioned for every alarm. After loading the default profile or another profile on the node, you can use the Clone feature to create custom profiles. After the new profile is created, the Alarm Profiles window shows the original profile—frequently Default—and the new profile.



Note

All default or user-defined severity settings that are Critical (CR) or Major (MJ) are demoted to Minor (MN) in non-service affecting situations as defined in Telcordia GR-474-CORE.



Tip

To see the full list of profiles including those available for loading or cloning, click the Available button. You must load a profile before you can clone it.

Wherever it is applied, the Default alarm profile sets severities to standard Telcordia GR-474-CORE settings. In the Inherited profile, alarms inherit, or copy severity from the next-highest level. For example, a card with an Inherited alarm profile copies the severities used by the node housing the card. If you choose the Inherited profile from the network view, the severities at the lower levels (node and card) are copied from this selection.

You do not have to apply a single severity profile to the node, card, and port level alarms. Different profiles can be applied at different levels. For example, you could use the inherited or default profile on a node and on all cards and ports, but apply a custom profile that downgrades an alarm on one particular card. Or you might choose to downgrade an OC-N unequipped path alarm (UNEQ-P) from Critical (CR) to Not Alarmed (NA) on an optical card because this alarm is raised and then clears every time you create a circuit. UNEQ-P alarms for the card with the custom profile would not display on the Alarms tab (but they would still be recorded on the Conditions and History tabs).

When you modify severities in an alarm profile:

- All Critical (CR) or Major (MJ) default or user-defined severity settings are demoted to Minor (MN) in Non-Service-Affecting (NSA) situations as defined in Telcordia GR-474-CORE.
- Default severities are used for all alarms and conditions until you create a new profile and apply it.

11.4.2 Alarm Profile Buttons

The Alarm Profiles window displays six buttons at the bottom. [Table 11-8](#) lists and describes each of the alarm profile buttons and their functions.

Table 11-8 Alarm Profile Buttons

Button	Description
New	Adds a new alarm profile.
Load	Loads a profile from a node or a file.
Store	Saves profiles on a node (or nodes) or in a file.
Delete	Deletes profiles from a node.
Compare	Displays differences between alarm profiles (for example, individual alarms that are not configured equivalently between profiles).
Available	Displays all profiles available on each node.
Usage	Displays all entities (nodes and alarm subjects) present in the network and which profiles contain the alarm. Can be printed.

11.4.3 Alarm Profile Editing

[Table 11-9](#) lists and describes the five profile-editing options available when you right-click an alarm item in the profile column.

Table 11-9 Alarm Profile Editing Options

Button	Description
Store	Saves a profile in a node or in a file.
Rename	Changes a profile name.
Clone	Creates a profile that contains the same alarm severity settings as the profile being cloned.
Reset	Restores a profile to its previous state or to the original state (if it has not yet been applied).
Remove	Removes a profile from the table editor.

11.4.4 Alarm Severity Options

To change or assign alarm severity, left-click the alarm severity you want to change in the alarm profile column. Seven severity levels appear for the alarm:

- Not-reported (NR)
- Not-alarmed (NA)
- Minor (MN)
- Major (MJ)
- Critical (CR)

- Use Default
- Inherited (I)

Inherited and Use Default severity levels only appear in alarm profiles. They do not appear when you view alarms, history, or conditions.

11.4.5 Row Display Options

In the network view, the Alarm Profiles window displays two check boxes at the bottom of the window:


- Hide reference values—Highlights alarms with non-default severities by clearing alarm cells with default severities. This check-box is normally greyed out. It becomes active only when more than one profile is listed in the Alarm Profile Editor window. (The check box text changes to “Hide Values matching profile Default” in this case.)
- Hide identical rows—Hides rows of alarms that contain the same severity for each profile.

11.4.6 Applying Alarm Profiles

In CTC node view, the Alarm Behavior window displays alarm profiles for the node. In card view, the Alarm Behavior window displays the alarm profiles for the selected card. Alarm profiles form a hierarchy. A node alarm profile applies to all cards in the node except cards that have their own profiles. A card alarm profile applies to all ports on the card except ports that have their own profiles.

At the node level, you can apply profile changes on a card-by-card basis or set a profile for the entire node. At the card view, you can apply profile changes on a port-by-port basis or set alarm profiles for all ports on that card. [Figure 11-2](#) shows an ONS 15310-MA CTX2500 card alarm profile. The ONS 15310-CL alarm profile window is similar.

Figure 11-2 Alarm Profile for a 15310-MA CTX2500 Card



11.5 Alarm Suppression

The following sections explain alarm suppression features for the ONS 15310-CL and ONS 15310-MA.

11.5.1 Alarms Suppressed for Maintenance

When you place a port in OOS,MT administrative state, this raises the alarm suppressed for maintenance (AS-MT) condition in the Conditions and History windows¹ and causes subsequently raised alarms for that port to be suppressed.

While the facility is in the OOS,MT state, any alarms or conditions that are raised and suppressed on it (for example, a transmit failure [TRMT] alarm) are reported in the Conditions window and show their normal severity in the Sev column. The suppressed alarms are not shown in the Alarms and History windows. (These windows only show AS-MT). When you place the port back into IS,AINS administrative state, the AS-MT condition is resolved in all three windows. Suppressed alarms remain raised in the Conditions window until they are cleared.

11.5.2 Alarms Suppressed by User Command

In the Provisioning > Alarm Profiles > Alarm Behavior tabs, the ONS 15310-CL and ONS 15310-MA have an alarm suppression option that clears raised alarm messages for the node, chassis, one or more slots (cards), or one or more ports. Using this option raises the alarms suppressed by user command, or AS-CMD condition. The AS-CMD condition, like the AS-MT condition, appears in the Conditions, and History¹ windows. Suppressed conditions (including alarms) appear only in the Conditions window—showing their normal severity in the Sev column. When the Suppress Alarms check box is unchecked, the AS-CMD condition is cleared from all three windows.

A suppression command applied at a higher level does not supersede a command applied at a lower level. For example, applying a node-level alarm suppression command makes all raised alarms for the node appear to be cleared, but it does not cancel out card-level or port-level suppression. Each of these conditions can exist independently and must be cleared independently.

**Caution**

Use alarm suppression with caution. If multiple CTC or TL1 sessions are open, suppressing the alarms in one session suppresses the alarms in all other open sessions.

11.6 External Alarms and Controls

External alarm physical connections are made with the ONS 15310-CL and ONS 15310-MA ALARM port. However, the alarms are provisioned using the 15310-CL-CTX and CTX2500 card view for external sensors such as an open door and flood sensors, temperature sensors, and other environmental conditions. External control outputs on the 15310-CL-CTX and CTX2500 cards allow you to drive external visual or audible devices such as bells and lights. They can control other devices such as generators, heaters, and fans.

1. AS-MT can be seen in the Alarms window as well if you have set the Filter dialog box to show NA severity events.

Provision external alarms in the 15310-CL-CTX and CTX2500 card view Provisioning > External Alarms tab and provision controls in the 15310-CL-CTX and CTX2500 card view Provisioning > External Controls tab. Up to 32 alarm contact inputs and 8 alarm contact outputs are available with the 15310-MA-CTX2500 cards. The 15310-CL-CTX cards report 3 alarm inputs and 2 alarm outputs.

11.6.1 External Alarm Input

You can provision each alarm input separately. Provisionable characteristics of external alarm inputs include:

- Alarm type
- Alarm severity (CR, MJ, MN, NA, and NR)
- Alarm-trigger setting (open or closed); open means that the normal condition is to have current flowing through the contact, and the alarm is generated when the current stops flowing; closed means that normally no current flows through the contact, and the alarm is generated when current does flow.
- Virtual wire associated with the alarm
- CTC alarm log description (up to 63 characters)



Note If you provision an external alarm to raise when a contact is open, and you have not attached the alarm cable, the alarm will remain raised until the alarm cable is connected.



Note When you provision an external alarm, the alarm object is ENV-IN-*nn*. The variable *nn* refers to the external alarm's number, regardless of the name you assign.

11.6.2 External Control Output

You can provision each alarm output separately. Provisionable characteristics of alarm outputs include:

- Control type
- Trigger type (alarm or virtual wire)
- Description for CTC display
- Closure setting (manually or by trigger). If you provision the output closure to be triggered, the following characteristics can be used as triggers:
 - Local NE alarm severity—A chosen alarm severity (for example, Major) and any higher-severity alarm (in this case, Critical) causes output closure
 - Remote NE alarm severity—Similar to local NE alarm severity trigger setting, but applies to remote alarms
 - Virtual wire entities—You can provision an alarm that is input to a virtual wire to trigger an external control output